



Moneen Industrial Estate, Castlebar, Co. Mayo. F23 XP99. Ireland.

T: +353 (0) 94 9024250

LRV (Light Reflective Values)

Test Standard: BS8493

Date Of Test: 18/ 12/2024

Tile Name : BLANCO GLOSSY

Tile Size: 30X60

Surface Finish: GLOSSY

9 Tests Were Carried Out On Each Tile : Yes

Number Of Tiles Tested: 1

Test Result: 81.57%

For & On Behalf Of Ceramic City:

This report relates only to the sample(s) tested.

*This report must not be reproduced in part without the written permission
of Ceramic City, Castlebar.*